

SOLICITATION NO. W911WN-05-B-0003

EMSWORTH LOCKS AND DAM  
BACK CHANNEL REHABILITATION  
OHIO RIVER, PENNSYLVANIA

A

M

E

N

D

M

E

N

T

NUMBER 6

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE		PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0006</div>		3. EFFECTIVE DATE <div style="text-align: center;">02-SEP-2005</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">W81ET4-5159-5022</div>		5. PROJECT NO. (If applicable)	
6. ISSUED BY US ARMY ENGR DISTRICT PGH WM S MOORHEAD FEDERAL BLDG 21ST FLOOR 1000 LIBERTY AVENUE PITTSBURGH PA 15222-4186 ARLENE M. BIGGER (412)395-7478		CODE <div style="text-align: center;">W911WN</div>		7. ADMINISTERED BY (If other than Item 6) US ARMY ENGR DISTRICT PGH 727 WM S MOORHEAD FEDERAL BLDG 1000 LIBERTY AVENUE PITTSBURGH PA 15222-4186		CODE <div style="text-align: center;">W911WN</div>	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP code)				(X)		9A. AMENDMENT OF SOLICITATION NO. <div style="text-align: center;">W911WN-05-B-0003</div>	
				X		9B. DATED (SEE ITEM 11) <div style="text-align: center;">29-JUL-2005</div>	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
(X)		A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
		B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO AUTHORITY OF FAR 43.103(b).					
		C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
		D. OTHER (Specify type of modification and authority)					
<b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
SEE ATTACHED							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)			

The following changes are made to the solicitation for Gate, Machinery and Electrical Replacement, Emsworth Dam – Back Channel, Ohio River, Allegheny County, Pennsylvania.

**Section 16910, Paragraph 2.2.2, is changed to read as follows:**

**2.2.2 PLC Processor Module**

~~One PLC Processor Module shall be provided for each unit installed at the project and shall be identical to that unit. The spare PLC processor shall be configured and programmed with the latest revision of ladder logic.~~ One PLC Processor Module shall be provided and shall be identical to the unit installed.

**AMENDMENT 0001, QUESTIONS AND ANSWERS SECTION**

The answer to the following question is revised:

**Q. The tenth and eleventh paragraphs in Specification 01100-1.12.1 (page 13) indicate the contractor is to rig, hoist and lower the aluminum bulkheads into the slots initially and the government will handle the bulkheads for all subsequent moves. If it is possible for the contractor to maneuver the bulkheads into position over the slots on a barge, will the Corps do the initial setting of the bulkheads using the overhead hoist system on the service bridge?**

~~A. Such movement of the bulkhead would be evaluated as part of the contractor's plan to position the bulkhead during the required coordination meeting.~~

As stated in Specification 001100-1.12.1, installation of the bulkhead units shall be the Contractor's responsibility with some limited assistance from the Government. The Contractor should not assume that the hoist will be available to assist with the setting of the bulkheads.

**THE FOLLOWING ARE NEW QUESTIONS**

**Q. We would like to request the electrical as-built drawings for the existing back channel electrical system. No reference drawings have been issued with the bid packages. The electrical is responsible for the removal of all decommissioned equipment associated with the existing electrical distribution/control system.**

A. As-built drawings for the Back Channel Dam electrical system are not available. Main Channel reference drawings of the electrical system are included in the solicitation package and are similar and typical to the Back Channel Dam.

**Q. In section 16910 (page 15), par. 2.2.2 it states that one PLC Processor Module must be supplied for each unit installed. This seems excessive and inconsistent with the other spare requirements. We believe it is a typo as and should read that a PLC Processor Module must be supplied for each different type of unit.**

A. Section 16910 paragraph 2.2.2 has been changed to read.... One PLC Processor Module shall be provided and shall be identical to the unit installed.